

Hellisay, Isle of Barra

Hydrographic Data Report: Deployment ID229

7th June to 13th August 2018

February 2022
Mowi Scotland Limited

CONTENTS

1.	INTRODUCTION.....	5
2.	MATERIALS & METHODS	6
	2.1 Bathymetry.....	6
	2.2 Current Data	6
	2.3 Magnetic Variation.....	7
	2.4 Data Processing.....	7
	2.5 Meteorological Data.....	10
4.	HYDROGRAPHIC DATA SUMMARY SHEETS	11
5.	SUMMARY OF CURRENT DATA – ID229	17
6.	CONCLUSION	18
	ANNEX 1. SURVEY EQUIPMENT DEPLOYMENT LOG	19

LIST OF FIGURES

Figure 1. Site location (top) and layout (bottom) and of the salmon farm near the Isle of Barra. The current meter deployment locations are marked by the black triangles.	5
Figure 2. Bathymetry in the region around the Hellisay salmon farm.	6
Figure 3. Mean intensity of the ADCP signal for the ID229 dataset plotted by bin number	9
Figure 4. Current Data Summary Sheet for the surface current cell 15, 17.7m from seabed, 7 th June to 13 th August 2018 inclusive (ID229).	11
Figure 5. Current Data Summary Sheet for the cage bottom current cell 5, 7.7m from seabed, 7 th June to 13 th August 2018 inclusive (ID229).	12
Figure 6. Current Data Summary Sheet for the near bottom current cell 1, 3.7m from seabed, 7 th June to 13 th August 2018 inclusive (ID229).	13
Figure 7. Cumulative Vector Plot of all velocity data from near surface cell for ID229.	14
Figure 8. Cumulative Vector Plot of all velocity data from cage bottom cell for ID229.	15
Figure 9. Cumulative Vector Plot of all velocity data from near bottom cell for ID229.	16
Figure 10. Summary of heading data from deployment ID229.	18
Figure 11. Summary of pitch and roll data from deployment ID229.	18
Figure 12. Pressure data from deployment ID229	18

LIST OF TABLES

Table 1: Sentinel V100 ADCP Specifications.	8
Table 2. Summary of current meter deployment	17
Table 3. Ranked percentiles for current speed at all three depths	17
Table 4. Major axis	17
Table 5. Mean and residual currents	17

QUALITY ASSURANCE

Mowi Scotland Ltd is ISO9001 and ISO14001 accredited and all project management follows policies designed to ensure that the collection, collation and reporting of information produced in the course of our operations is done to a consistently high standard meeting the requirements of the end user.

1. Introduction

Mowi Scotland Ltd. is preparing an application to the Scottish Environmental Protection Agency (SEPA) for a technical variation to CAR/L/1095612 to modify an existing salmon farm site located at Hellisay, near the Isle of Barra. Mowi Scotland Ltd. propose to change the existing site from 12 x 120 m circumference pens, with 12 m deep nets, held in a 70 m grid (Figure 1) to 5 x 200 m circumference pens with 10 m deep nets, held in a 110 m grid.

Mowi Scotland Ltd have carried out hydrographic surveys at the site in 2018. Hydrographic data at Hellisay was gathered during this time in two deployments:

- i. 7th June 2018 to 13th August 2018 (ID229)
- ii. 13th August to 30th October 2018 (ID239)

This report describes the data from the 7th June to 13th August 2018 deployment at Hellisay. The purpose of this report is to assess the suitability of the collected hydrographic data for calibration of a hydrodynamic model of the South Uist & Barra region and input into the NewDepomod model.



Figure 1. Site location (top) and layout (bottom) and of the salmon farm near the Isle of Barra. The current meter deployment locations are marked by the black triangles.

2. Materials & Methods

2.1 Bathymetry

Bathymetry for the study area was taken from the UKHO INSPIRE bathymetry data (<http://aws2.caris.com/ukho/mapViewer/map.action>).




Figure 2. Bathymetry in the region around the Hellisay salmon farm.

2.2 Current Data

Mowi staff carried out hydrographic surveys at the site during 2018. The purpose of this hydrographic report is to assess the suitability of the collected hydrographic data for use with the NewDepomod and Hydrodynamic models. The data contained in this report were recorded at the site from 7th June to 13th August 2018 (66 days and 21 hours of data; deployment ID229). The data from another deployment (ID239) are presented in a separate hydrographic report.

The Sentinel V100 (Wide) ADCP (Table 1), within its mooring frame, was positioned at 57.00428N, -7.34083W (75874E 803037N), which was approximately 450m from the nearest shoreline and approximately 160m from the centre of the proposed cage group (Figure 1). The transducer head was 70 cm from the base of the mooring frame. The mean depth (derived from the pressure sensor) at the Sentinel V100 ADCP position was 23.18 m.

Initial soundings were taken to establish the possible depth the Sentinel V100 ADCP would be situated at during high tide and so that the most appropriate cell size could be determined. The cell size was set at 1.0 m and the number of cells to 49.

Data was automatically written and stored to the internal memory within the Sentinel V100 ADCP main body and then downloaded to computer after completion of the deployment period via WiFi.

2.3 Magnetic Variation

No magnetic variation correction was made to the Sentinel V100 ADCP during deployment, this was undertaken to the data after the instrument was recovered and data downloaded. The magnetic variation used was -4.13° ; this was determined using the World Magnetic Model, produced jointly with the US National Oceanographic and Atmospheric Administration's National Geophysical Data center. Further details can be found at <http://www.geomag.bgs.ac.uk/navigation.html>

2.4 Data Processing

Upon retrieval of the Sentinel V100 ADCP current meter, all data was downloaded to a computer for analysis. The raw data file was opened in Teledyne's "Velocity" software and Matlab. Deployment diagnostic data (beam intensity, correlation, pitch and roll) were analysed to confirm that the deployment was successful with the instrument orientated upright. The heading data were also examined to identify any movement of the Sentinel V100 ADCP mooring frame during the deployment.

The diagnostic data suggested that velocities from the first 15 bins were valid (Figure 3). Calculations were undertaken to identify the cells to be used for surface and middle currents. Surface data was taken at an average depth (derived from the pressure sensor) of 3.27 m (cell 15), and cage-bottom data at 13.27 m (cell 5). Surface and middle cell heights were 17.73 m and 7.73 m from the seabed respectively. The bottom cell (cell 1) was at a depth of 17.27 m and 3.73 m above the seabed.

Table 1: Sentinel V100 ADCP Specifications.

Depth Cell Size ¹		V20 (1000kHz)		V50 (500kHz)		V100 (300kHz)	
		Range (m) ^{2,3} Wide/Narrow	Std Dev (cm/s) ^{3,4} Wide/Narrow	Range (m) ^{2,3} Wide/Narrow	Std Dev (cm/s) ^{3,4} Wide/Narrow	Range (m) ^{2,3} Wide/Narrow	Std Dev (cm/s) ^{3,4} Wide/Narrow
	0.25m	18.0/22.6	19.2/36.5				
	0.3m	19.3/24.0	11.1/20.8				
	0.5m	20.2/24.9	7.1/13.4	44.1/57.6	19.2/36.5		
	1.0m	22.1/26.9	3.6/6.7	50.5/64.6	7.1/13.5	94.5/120.6	10.9/20.6
	2.0m	24.5/29.4	1.7/3.2	56.0/70.6	3.6/6.7	103.5/130.4	5.5/10.3
	4.0m	26.9/32.0	0.8/1.6	63.1/78.2	1.7/3.2	114.6/142.3	2.7/5.2
	6.0m			67.4/82.8	1.1/2.1	121.7/151.5	1.8/3.3
Communications and Recording	Wireless Internal memory	802.11b/g/n One 16GB Micro SD Card included					
Profile Parameters	Velocity accuracy Velocity resolution Velocity range Ping rate	V20/V50: 0.3% of the water velocity relative to the ADCP ±0.3cm/s V100: 0.5% of the water velocity relative to the ADCP ±0.5cm/s 0.1cm/s ±5m/s (default); ±20m/s (maximum) Up to 4Hz					
Echo Intensity Profile	Vertical resolution Dynamic range Precision	Depth cell size 80dB ±1.5dB					
Transducer and Hardware	Beam angle Configuration Depth rating Materials	25° 4-beam, convex; 5th beam vertical 200m Transducer, housing, and end cap: plastic Connector: metal shell					
Standard Sensors	Temperature (mounted on transducer) Compass (magneto-inductive sensor) Tilt (MEMS accelerometers) Pressure sensor (mounted on transducer)	Range -5° to 45°C, precision ±0.4°C, resolution 0.1° Accuracy 2° RMS, resolution 0.1°, max. dip angle 85° Pitch range ±90°, roll range ±180°, accuracy 2° RMS, precision 0.05° RMS, resolution 0.1° Range 300m, accuracy 0.1%FS					
Power	External DC input Internal battery voltage Battery capacity; over-the-counter @0°C Battery pack @5°C	12–20VDC 18VDC new 100 watt hours (typical) 510 watt hours					
Software	Teledyne RDI's new software included	ReadyV—Pre-deployment (testing, planning, and data recovery) ⁵ Velocity—Post-processing (data handling, display, and export) ⁶					
Environmental	Standard depth rating Operating temperature Storage temperature (without batteries) Weight in air Weight in water	200m -5° to 45°C -30° to 60°C 7.5kg – 16.0kg 1.6kg – 6.0kg					
Available Options	External battery case • AC/DC power converter • 5th beam (at time of order only) • Waves processing • Straight or right-angle metal shell connector						
Dimensions	Special configuration drawing available upon request						

1. User's choice of depth cell not limited to the typical values specified.
2. Ranges specified are typical at temperature of 5°C and salinity of 35psu; longer ranges are possible.
3. User selects the bandwidth mode; wide = 25% or narrow = 6%.
4. Standard deviations (Std Dev) are typical values for single ping data.
5. Resident in ADCP accessed via a web browser.
6. Windows™ based software program.




Figure 3. Mean intensity of the ADCP signal for the ID229 dataset plotted by bin number

The ‘first cell range’ is automatically calculated by the instrument, which is the distance from the transducer head to the first cell. For this deployment, the first cell range was calculated as 3.03 m. This value is then added to the height of the instrument frame (0.7 m) to get the first cell height above the seabed, which equated to 3.73 m

Standard deviation has been assessed throughout the deployment to identify accurate and reliable data for near bed, middle (net depth) and surface cells using the following equation:

$$Cell\ StdDev = \frac{Instrument\ StdDev}{\sqrt{No.\ valid\ pings}} \quad (1)$$

The Instrument Standard Deviation (StdDev) in Equation 1 is determined using the deployment settings when the meter is programmed, examples of the StdDev values for different configurations are shown in Table 1. This deployment had a cell size of 1m which equates to an Instrument StdDev of 10.9 cm/s.

The Percentage of valid pings used to calculate Cell StdDev is derived using “Percentage Good” data which allows us to relate the StdDev to the actual data gathered. The percent good data is available for 1, 2, 3 and 4 beams which represent the following:

- Percent good 1 = % of good data computed from 3 Beams
- Percent good 2 = % of bad data due to more than 2 Beam bad
- Percent good 3 = % of bad data due to error velocity exceeded
- Percent good 4 = % of good data computed from 4 Beams

The method described has been used to calculate the Standard deviation throughout the deployment for the surface, middle and bottom cells; the average StdDev values for the surface, middle and bottom was 0.63cm/s, 0.63cm/s and 0.65cm/s respectively which are all within the SEPA criteria of 2cm/s.

2.5 Meteorological Data

The collection of meteorological data is no longer required to support the assessment process and consequently has not been undertaken. The current data used is collected using multiple deployments and over a longer period and thus provides a more realistic representation of site conditions than short deployments, thus allowing an assessment of the influence of meteorological conditions.

3. Results and Discussion

A summary of the current data is shown in Figure 4 to Figure 12 and in Table 2 to Table 5. Over the period analysed for this report, the near-surface, middle and bottom cells had current speed averages of 9.07 cm/s, 6.61 cm/s and 5.73 cm/s respectively. This gave an overall average of 7.13 cm/s. The orientation of the tidal velocities was north-west – south-east.

Residual currents at the surface (108°G, Figure 7) was toward south east while the mid-depth and near-bottom cells were toward the north-west (302°G and 296°G respectively, Figure 8 & Figure 9). The magnitude of the residual currents for the surface, middle and bottom cells were moderate, with mean values of 0.016 m/s, 0.028 m/s and 0.015 m/s respectively.

4. Hydrographic Data Summary Sheets




Figure 4. Current Data Summary Sheet for the surface current cell 15, 17.7m from seabed, 7th June to 13th August 2018 inclusive (ID229).




Figure 5. Current Data Summary Sheet for the cage bottom current cell 5, 7.7m from seabed, 7th June to 13th August 2018 inclusive (ID229).




Figure 6. Current Data Summary Sheet for the near bottom current cell 1, 3.7m from seabed, 7th June to 13th August 2018 inclusive (ID229).




Figure 7. Cumulative Vector Plot of all velocity data from near surface cell for ID229.




Figure 8. Cumulative Vector Plot of all velocity data from cage bottom cell for ID229.




Figure 9. Cumulative Vector Plot of all velocity data from near bottom cell for ID229.

5. Summary of Current Data – ID229

Site Name: Hellisay
 Data start date: 07/06/2018
 Data end date: 13/08/2018
 Mean Water Depth: 23.81m

Table 2. Summary of current meter deployment

	Cell	Depth Below Surface (m)	Distance from Seabed (m)	Mean current speed (cm/s)
Near surface:	15	3.27	17.73	9.07
Cage bottom:	5	13.27	7.73	6.61
Near bed:	1	17.27	3.73	5.73
Average current speed:				7.13

Table 3. Ranked percentiles for current speed at all three depths

Cell	Ranked Percentile (%) for mean speed	≤3cm/s (%)	≥4.5cm/s (%)	≥9.5cm/s (%)
Near surface:	59	10	78	38
Cage bottom:	61	23	59	22
Near bed:	64	37	48	19

Table 4. Major axis

Cell	Major Axis (Deg-G)
Near surface:	130
Cage Bottom:	300
Near bed:	290

Table 5. Mean and residual currents

Cell	Mean Speed (m/s)	Residual Speed (m/s)	Residual Parallel (m/s)	Residual Normal (m/s)	Tidal Amplitude Parallel (m/s)	Tidal Amplitude Normal (m/s)
Near Surface:	0.091	0.016	0.015	-0.006	0.140	0.051
Cage Bottom:	0.066	0.028	0.028	0.001	0.101	0.038
Near Bed:	0.057	0.015	0.015	0.002	0.100	0.031




Figure 10. Summary of heading data from deployment ID229.




Figure 11. Summary of pitch and roll data from deployment ID229.




Figure 12. Pressure data from deployment ID229

6. Conclusion

MOWI has collected and analysed current and bathymetric data for the proposed technical variation at the Muck fish farm. The analysed current data for the 66 days and 21 hours period are believed to be reliable and representative of the proposed location. The bathymetric data from the wider-area UKHO bathymetry data provided a coherent bathymetric dataset for the site.

Annex 1. Survey Equipment Deployment Log

Location:	Hellisay
Nearest tidal port:	Barra North Bay
Time zone:	UTC
Meter switched on:	10:00 07/06/2018
Meter switched off:	09:00 13/08/2018
Period used for this report:	10:20 07/06/2018 – 08:20 13/08/2018
ADCP serial number:	24616
Meter position:	57.00428N, -7.34083W 75874 E 803037 N
Minimum water depth:	21 m (20.3m measured by ADCP + 0.7 m *)
Water depth (Chart Datum):	20.80 (minimum water depth - 0.2 m tide timetable)
Mean water depth:	23.18 m (22.48 measured by ADCP + 0.7 m *)
Depth of meter from surface:	20.10 m (below chart datum to transducer)
Height of meter from seabed:	0.7 m to transducer head
Sounding at deployment:	22 m @ 11:20 on 07/06/2018

Table A1. ADCP meter settings:

Reference:	Transducer
Bin size (m):	1.0
Dist to 1 st bin (m):	3.03
Number of bins:	49
Frequency (kHz):	307
Recording interval (mins):	20
No. pings per ensemble:	300
Magnetic correction:	0
Ensemble:	300
Standard Deviation (cm/sec):	0.63
Time/Ping (seconds):	2