

Non-Technical Summary (full version in Draft Decision Document)

This variation will permit the relocation of the sites Effluent Treatment Plant (ETP), incorporating effluent balance tank, sludge tank, Dissolved Air Flotation (DAF) unit and associated equipment to another area within the current site boundary.

New pumping pipework will be installed from the current screening equipment to the new effluent treatment plant. As part of the relocation works a new, larger, balancing tank and sludge tank will be installed.

Discharge volumes to the sewer will not increase but the larger balance tank will allow for a greater retention period of untreated effluent and minimise variations in the effluent flow and composition, producing greater consistency in discharge quality.

The current discharge location point to the Scottish Water sewer will remain in the same location.